

IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761-2816
(909) 472-4100 • Fax (909) 472-4244 • www.iapmo.org



LISTED PRODUCTS

Effective Date : April 2006 Void After: April 2007

Product: **Anti-Scale Water Conditioning Appliance** File No. 4940

Issued To :
STERLING WATER SYSTEMS LLC
123 S. MARKET STREET
WICHITA, KS 67202

IDENTIFICATION: Manufacturer's name or trademark, model number, size and the UPC® certification mark.

CHARACTERISTICS: Electrical anti-scale water conditioning appliance intended to treat potable water systems. To be installed in accordance with the manufacturer's instructions, other IAPMO listed components and the latest edition of the Uniform Plumbing Code.

Manufactured in compliance with IGC 91-2006.

MODELS:

<u>Model No.</u>	<u>Description</u>
ICT-20	Water conditioning device, 1-20 GPM w/ 1" unions
ICT-30	Water conditioning device, 2-30 GPM w/ 1-1/4" unions
ICT-38	Water conditioning device, 4-60 GPM w/ 1-1/2" fittings
ICT-70	Water conditioning device, 9-120 GPM w/ 2" fittings
ICT-110	Water conditioning device, 10-500 GPM w/ 4" fittings
ICT-150	Water conditioning device, 20-1000 GPM w/ 6" fittings

ADDITIONAL COMPANIES:

ADDITIONAL
COMPANY INFO:

AUTHORIZATION TO MARK

This authorizes the application of the Certification Marks shown below to the models described in the Products(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to the multiple listee model(s) identified on the correlation page of the Listing Report.

Applicant: Sterling Water Systems
123 South Market St.
Wichita, KS 67202, USA

Contact: Name: Mr. Thomas Martin Phone: 316-262-5191

Manufacturer: Same as Applicant

Party Authorized To Apply Mark: Same as Manufacturer

Report Issuing Office: Intertek Richardson, TX

Report No.: 3093962DAL-001

Product Covered: Water conditioner, models ICT-10, ICT-20, ICT-30, ICT-38, ICT-70, ICT-110, ICT-150 and ICT-225

Description: The product covered by this report is hard water treatment unit. The water system utilizes electro-kinetic technology to treat minerals found in hard water. System help reduces scale buildup in areas such as tubs, showers, and sinks by inhibiting mineral crystallization and scale formation. The system is provided with a remotely attached brick power supply. Power supply is provided with a detachable cord-set. Equipment intended to be in-door use only.

Standard(s): Safety Motor-Operated Appliances, (UL 73, 8th Ed. 09/09/98)
Safety Subject Standard for Water Softeners and Demineralizers, (UL Subject 979, Issue Number 1, June 1982)

This document is the property of Intertek Testing Services and is not transferable. Only the Applicant may reproduce this document. The certification mark(s) may be applied only at the above noted location of the Party Authorized To Apply Mark.



Authorized by: Michelle Lake for Date: March 22, 2006
William T. Starr, Certification Manager

Control Number: 3060742

This document supersedes all previous Authorizations to Mark for the noted Report number.

Intertek Testing Services NA Inc.
165 Main Street, Cortland, NY 13045
Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699